



ADMINISTRADOR DEL MERCADO MAYORISTA

PROGRAMA DE DESPACHO
SABADO 08 DE JUNIO

QUIXAL: ENERGÍA MÁXIMA SEGÚN PROGRAMA
INGENIOS: RESTRICCIÓN ARRANQUE - PARADA

Intercambio

REGULACION PRIMARIA: LOS GENERADORES DEBEN MANTENER COMO RESERVA REGULANTE UN 3% DE LA POTENCIA GENERADA

Main data table with columns for time intervals (DE, A), power (POT. MAX, POT. DISP, POT. POR UNIDAD), energy (ENERGIA), various generator units (CHX, AGU, JUR, LES, SMA, POR, M, RBO, SEC, PAS, PVE, G3, G5, EVAP, ORZ, LVA, LVAP, TG1, TG2, TG4, W1, W2, W3, W4, W5, GAS, PNT, CON, MAG, LUN, MTI, SAA, TUL, TDL, SJO, ENR, ESP, TAM, SID1, SID2, GEN), and reserves (RESERVA OPERATIVA, RESERVA OPERATIVA MW), along with percentages and MW values.

MANTENIMIENTO PROGRAMADO: Table listing maintenance events for units like ESPERANZA UNA UNIDAD, LAS PALMAS 4, CHIXOY 2 PRUEBAS, ENRON 4, ENRON 18, and GENOR 3 Y 4, including start/end times and durations.

INDISPONIBILIDAD FORZADA: Table listing forced outages for units like ESCUINTLA GAS 2,4, AGUACAPA 1, SIDEGUA UN. 3, and EL SALTO 2, including start/end times and durations.

Hora: 8:07
MANUEL MEDINA
OPERACIÓN EN TIEMPO REAL